



Certificate of Compliance

This certificate is issued for the following:

System Designation:	HI-FOG GPU Water Mist System for the Protection of Combustion Turbines and Machinery in Enclosures with Volumes up to, and Including, 48,600 ft ³ (1,375 m ³) and a Maximum Height of 36.1 ft (11.0 m).
Design, Installation, Operation and Maintenance Manual:	HI-FOG® Systems (GPU) for Protection of Machinery and Combustion Turbines In Enclosures with Volumes up to, and Including 1375 m ³ [48600 ft ³], Design, Installation, Operation, and Maintenance Manual, Document Ref. MO/ES/33/DIOM/FM/12, Version 1.0, May '13

Prepared for:

MARIOFF CORPORATION OY
VIRNATIE 3
FIN-01301
VANTAA, FINLAND

Manufactured at:

MARIOFF CORPORATION OY
MOREENITIE 4
FIN-04250
KERAVA, FINLAND

FM Approvals Class: 5560

Approval Identification: 3046251 Approval Granted: May 24, 2013

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in dark ink, appearing to read 'Richard B. Dunne', written over a horizontal line.

Richard B. Dunne
Group Manager – Fire Protection Group
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062



Member of the FM Global Group